



City of Coppel
Building Inspections Dept.
265 E Parkway Blvd
Coppell, TX 75019

Phone: (972) 304-3500
Fax: (972) 462-5318

RACKING PERMIT SUBMITTAL REQUIREMENTS

Submittal requirements:

- Overall layout of space and racking
- Engineering on floor anchoring
- Commodity Type
- Aisle Width
- Storage Heights
- Distance from the top of storage to sprinkler head deflector
- Flue Spacing
- Shelving Type
- Overall useable height to ceiling

Rev. September 2016